



**GOVERNMENT OF TELANGANA
DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From The District fire officer, Nagarkurnool District.	To, G Shankaraiah, Kotra X Road, Veldanda Mdl, Nagarkurnool Dist, Telangana,
------------------------------------------------------------------	---------------------------------------------------------------------------------------------

Ack. No. 539250002024 Dated: 24/08/2024

Sir, Sub:	<p>TELANGANA DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Nagarkurnool District. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Shastra School, Sy.No-470, Kotra X Road,/-Kotra/Veldanda/Nagarkurnool , – Regarding.</p>	
--------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------

Ref:	<p>1. Acknowledgement No 539250002024 2. This Office NOC for Occupancy Ack/RC No. Rc.No.687/A2/2014 dt. 24/08/2024 3. Non Multi storeyed Building Inspection Committee Report,, Ack. No. 539250002024, dt. 24/08/2024</p>
------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Shastra School, Sy.No-470, Kotra X Road,/-Kotra/Veldanda/Nagarkurnool**
- 2) The above said building was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy
- 4) Open Spaces: The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	7
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	7
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to	30.00	30.00



**GOVERNMENT OF TELANGANA
DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



	an Exit.		
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	15.00	15.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	0.00	0	Ground	Ground

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	1450.00	EDUCATIONAL B-1 Schools up to senior secondary level	362.00	7.25	10.00
2	1st Floor	1450.00	EDUCATIONAL B-1 Schools up to senior secondary level	200.00	2.00	2.00

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	8.00	0.00	0.00	0.00	0.00
2	1st Floor	8.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	16	16

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

approved

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Shastra School, Sy.No-470, Kotra X Road, -Kotra/Veldanda/Nagarkurnool** with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-	All occupants shall be trained	Mock drills should be conducted once in 3




**GOVERNMENT OF TELANGANA
DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



	functioning of fire safety measures and other installations shall be the responsibility of the management.	to operate the fire safety equipment during emergency.	months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.


 Signed By : Mr. P. Giridhar Reddy
 Designation : District Fire Officer ,Nagarkurnool
 Date : 24-08-2024
 Nagarkurnool District.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"